

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014780.03-R1
DATE: 07/28/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Intus
CODE: 1817-1
REVISION DATE: 09/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Intus Windows, LLC 2720 Prosperity Avenue, 400-1 Fairfax, VA 22031	Series "Supera" Polymer Inswing Casement Window Configuration: X Glazing: IG-5/32" Annealed Glass/Trosifol 4 PVB Interlayer/ 5/32" Annealed Glass/ 1/4" Tempered Glass Frame: W-902mm(35.50") H-1500mm(59.06") Vent: W-826mm(32.50") H-1424mm(56.06") DLO: W-670mm(26.38") H-1264mm(49.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-19/ASTM E1996-20 TAS 201/202/203-94	Class CW-PG70 902 x 1500 (36 x 59)-C Design Pressure: ± 3360 Pa (± 70 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf) Wind Zone 4 - Missile Level A Small Missile Impact Rated

Product Tested By: Molimo Architectural Product Testing
Report No: 12190.02-106-13/12190.03-106-13/12190.04-106-13
Expiration Date: March 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023