

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014780.04
DATE: 09/26/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Intus
CODE: 1817-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Intus Windows, LLC 2720 Prosperity Avenue, 400-1 Fairfax, VA 22031	Series “Supera” Vinyl Inswing Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-902mm(35.50") H-1500mm(59.06") Vent: W-826mm(32.50") H-1424mm(56.06") DLO: W-670mm(26.38") H-1264mm(49.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG70 902 x 1500 (36 x 59)-C Design Pressure: ±3360 Pa (±70 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)

Product Tested By: Molimo Architectural Product Testing
Report No: 12190.03-106-13/W-2081
Expiration Date: March 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com