



CERTIFICATION

6300 Enterprise Lane | Madison, WI 53719 | drjcertification.org



Issue Date: October 16, 2023

Certificate of Code Compliance

This Certificate of Code Compliance is issued by DrJ Engineering, LLC (DrJ), within the scope of the evaluation listed below. This evaluation is based on standardized evaluation of the product conducted by DrJ, an accredited ANAB ISO/IES 17065 agency listed with the Florida Building Commission as a Product Certification Agency.

This certificate indicates the product is compliant with the Florida Building code for the scope of application.

Manufacturer Information	Products Certified
Carlisle SynTec Systems 800-479-6832 1285 Ritner Hwy Carlisle, PA 17013-9381 robert.patton@carlisleccm.com www.carlisesyntec.com	VacuSeal™ Roof Vent

Referenced Standards

ASCE/SEI 7	2022
UL 1897	2015

Scope of Evaluation

Performance of VacuSeal™ Roof Vent for resistance to wind uplift forces used with modified bitumen and single-ply roof membranes installed on low-slope roofs. Performance for use in HVHZs is approved based on the product uplift resistance of 195 psf.

Authorized Signature

Larry Wainright | Vice President Product Certification
DrJ Engineering, LLC
6300 Enterprise Lane
Madison, WI 53719
lwainright@drjengineering.org
608-310-6742