NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI014955.06
DATE: 10/30/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products **504 Highway 63 South** **Freeburg, MO 65035**	**Series "C600/C605 One Tone"** **Aluminum Awning Out-Swing** **Roto Window** Configuration: X Glazing: Insulated Glass (Annealed) Frame: W-1829mm(72") H-1219mm(48") Vent: W-1792mm(70.56") H-1186mm(46.69") DLO: W-1683mm(66.25") H-1076mm(42.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	**Class AW-PG70 1829 x 1219 (72 x 48)-AP** **Design Pressure: ±3360 Pa (70 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)**

Product Tested By: Intertek - Plano, Texas
Report No: L0637.01-801-47/W-2076/W-2089
Expiration Date: **June 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com