



Issue Date: June 16, 2026

Certificate of Code Compliance

This Certificate of Code Compliance is issued by DrJ Engineering, LLC (DrJ), within the scope of the evaluation listed below. This evaluation is based on standardized evaluation of the product conducted by DrJ, an accredited ANAB ISO/IES 17065 agency listed with the Florida Building Commission as a Product Certification Agency.

This certificate indicates the product is compliant with the Florida Building code for the scope of application.

Manufacturer Information	Products Certified
Versico Roofing Systems 800-992-7663 PO Box 1289 Carlisle, PA 17013-6289 robert.patton@versico.com www.versico.com	VacuSeal™ Roof Vent

1 Referenced Standards

ASCE/SEI 7	2022
UL 1897	2015

2 Scope of Evaluation

Performance of VacuSeal™ Roof Vent for the ability to resist wind uplift forces when used with single-ply roof membranes installed on low-slope roofs. Performance for use in HVHZ is approved based on the product uplift resistance of 195 psf.

3 Authorized Signature

Chris Scoville | Vice President Product Certification
DrJ Engineering, LLC
6300 Enterprise Lane
Madison, WI 53719
cscoville@qualtim.com
608-310-6720