



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

Great Day Improvements, LLC
12121 Champion Way
Cincinnati, OH 45241

Attn: Martin Goss

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S. 2/A440-17 R-PG40-1600x1118 (63x44)-HS Negative Design Pressure = -50 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Great Day Improvements, LLC Code: CWM	21310	JANUS HS (PVC)(XX)(OG)(INS GL) (REINF)(ASTM)	<u>FRAME</u> 1600 mm x 1118 mm (5'3" x 3'8")	<u>SASH</u> 765 mm x 1030 mm (2'6" x 3'5")


This Certification will expire **May 31, 2028** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Intertek B&C**

Report No.: **P8304.01-501-47**

Date of Report: **August 24, 2023 (Revised September 5, 2023)**

Evaluated for Certification: **September 11, 2023**


Associated Laboratories, Inc.

Authorized for Certification: **September 11, 2023**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)