

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016481.01
DATE: 03/17/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Lippert
CODE: 206-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lippert Components, Inc. 5001 North Graham Street Charlotte, NC 28269	Series "3930/3950" Vinyl Horizontal Sliding Window (New Constr. & Replacement Impact Rated) Configuration: XO Glazing: IG-Ext. 1/8" Annealed Glass/Int. 1/8" Tempered Glass/0.090" Saflex PVB Interlayer/1/8" Tempered Glass Frame: W-1829mm(72") H-1524mm(60") Sash: W-895mm(35.25") H-1435mm(56.50") DLO: W-826mm(32.50") H-1359mm(53.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-19 ASTM E1996-20	Class LC-PG50 1829 x 1524 (72 x 60)-HS Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Missile Level D - Wind Zone 3

Product Tested By: Intertek, PLC
Report No: T1034.01-501-44
Expiration Date: December 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway
Hayes, VA 23072**

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023