

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016235.01-R1
DATE: 02/18/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Lippert
CODE: 206-1
REVISION DATE: 09/18/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lippert Components, Inc. 5001 North Graham Street Charlotte, NC 28269	Series "Impact 3750 REP/3850 NC" Vinyl Outswing Casement Window (New Construction & Replacement Frame) Configuration: X Glazing: IG-Ext. 1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass/Int. 1/8" Annealed Glass Frame: W-914mm(36") H-1829mm(72") Vent: W-865mm(34.06") H-1780mm(70.06") DLO: W-752mm(29.63") H-1667mm(65.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09 ASTM E1886-05 ASTM E1996-04/05/06	Class LC-PG50 914 x 1829 (36 x 72)-C Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf) Canadian Air Infiltration/Exfiltration Level: A3 Missile Level D - Wind Zone 4

Product Tested By: Intertek, PLC
Report No: I3879.05-501-44/I6397.05-501-44/C1823.01-501-44
Expiration Date: **January 31, 2032**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023