

Prepared Roof-covering Materials, Formed or Molded Metal, Fiber-Cement, Plastic or Fire-retardant-treated Wood

COMPANY

Weatherlok Metal Roofing System Corp

Po Box 129

Gilford, MT 59525 United States

R40581

Formed metal shingles, for installation as Class A prepared roof covering. Limited to 15/32 in. plywood or minimum 7/16 in. thick OSB decks and one layer of minimum 1/4-in. thick Georgia-Pacific Gypsum LLC "DensDeck® Roofboard" with all joints staggered a min of 6 in. from the plywood joints covered with "Interlocking Shake Panel". May also bear the statement "Degree of wind resistance investigated in accordance with procedures adapted from ASTM D3161 at a wind speed of 110 mph". The fasteners used with these panels are No. 14 x 1-1/2 in. long screws, screwed through the top strip spaced per the pre-drilled holes in the strip.

Last Updated on 2023-12-12

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."