

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016190.04
DATE: 05/21/2026
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series “La Cantina Doors” Aluminum Dual Inswing Side Hinged Doors (w/Transom & Sidelites) Configuration: O/OXXO Glazing: Insulating Glass (Tempered) Frame: W-3658mm(144") H-3353mm(132") Panel: W-1065mm(41.93") H-2672mm(105.20") DLO: W-960mm(37.80") H-2565mm(100.98")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class LC-PG25 3658 x 3353 (144 x 132)-SHD Design Pressure: ±1200 Pa (±25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Intertek, PLC
Report No: T4379.01-303-44
Expiration Date: **March 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023