NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016190.05**
DATE:	**05/21/2026**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**Series "La Cantina Doors"** **Aluminum Dual Outswing** **Side Hinged Doors** **(w/Transom & Sidelites)** Configuration: O/OXXO Glazing: Insulating Glass (Tempered) Frame: W-3658mm(144") H-3353mm(132") Panel: W-1085mm(42.72") H-2672mm(105.20") DLO: W-960mm(37.80") H-2565mm(100.98")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class LC-PG35 3658 x 3353 (144 x 132)-SHD** **Design Pressure: ±1680 Pa (±35 psf)** **Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)**

Product Tested By: Intertek, PLC
Report No: T2166.01-303-44
Expiration Date: **December 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com