

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016190.03-R1
DATE: 09/09/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 08/10/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series “La Cantina Doors” Aluminum Dual Inswing Side Hinged Doors Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-2290mm(90.16") H-3666mm(144.33") Panel: W-1099mm(43.27") H-3586mm(141.18") DLO: W-994mm(39.13") H-3482mm(137.09")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG25 2290 x 3666 (90 x 144)-SHD Design Pressure: 1200 Pa (25 psf) Positive Design Pressure: 1440 Pa (30 psf) Negative Design Pressure: 1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Intertek, PLC
Report No: R1986.01-303-44
Expiration Date: **July 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023