

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015873.02
DATE: 04/29/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Enerlux
CODE: 2426-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Enerlux Windows & Doors, LLC 1530 Pine Avenue Crete, NE 68333	Series "825 Casement 42 x 84" Fiberglass Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1067mm (42") H-2134mm (84") Panel: W-1029mm (40.50") H-2096mm (82.50") DLO: W-922mm (36.28") H-1988mm (78.28")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19 CSA A440S1-17	Class LC-PG50 1067 x 2134 (42 x 84)-C Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Quast Consulting & Testing, Inc.

Report No: QCT24-7231.01

Expiration Date: March 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023