NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016236**
DATE:	**08/12/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Downey**
CODE:	**2944-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Downey Glass, LLC **1100 Northwest 15th Avenue** **Pompano Beach, Florida 33069**	**Series "DG-100"** **Aluminum Double Side Hinged Doors** **w/Transom & Sidelite** Configuration: OO/XXO Glazing: IG-1/4" Heat Strengthened Glass/0.090" Trosifol PVB Interlayer by Kuraray/1/4" Heat Strengthened Glass Frame: W-3810mm(150") H-3658mm(144") Panel: W-1219mm(48") H-3048mm(120") DLO: W-903mm(35.56") H-2635mm(103.75")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 **TAS 202-94 (Structural Only)** **ASTM 1886-19** **ASTM 1996-23**	**Design Pressure: ±2640 Pa (±55 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)** **Missile Level D** **Large Missile Impact Rated**

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-DGG-23-001
Expiration Date: **May 31, 2028**

Administrator's Signature:_____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com