

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016237
DATE: 08/12/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Downey
CODE: 2944-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Downey Glass, LLC 1100 Northwest 15th Avenue Pompano Beach, Florida 33069	Series "DG-100" Aluminum Double Side Hinged Doors Configuration: XX Glazing: IG-1/4" Heat Strengthened Glass/0.090" Trosifol PVB Interlayer by Kuraray/1/4" Heat Strengthened Glass Frame: W-2438mm(96") H-3048mm(120") DLO: W-903mm(35.56") H-2635mm(103.75")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 TAS 202-94 (Structural Only) ASTM 1886-19 ASTM 1996-23	Design Pressure: ±2640 Pa (±55 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Missile Level D Large Missile Impact Rated

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-DGG-23-001
Expiration Date: May 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023