

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016238-R1
DATE: 08/12/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Downey
CODE: 2944-1
REVISION DATE: 11/04/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Downey Glass, LLC 1100 Northwest 15th Avenue Pompano Beach, Florida 33069	Series "DG-300" Aluminum Window Wall Configuration: OOO Glazing: IG-1/4" Heat Strengthened Glass/0.090" Trosifol PVB Interlayer by Kuraray/1/4" Heat Strengthened Glass Frame: W-4572mm(180") H-3658mm(144") Panel: W-1524mm(60") H-3658mm(144") DLO: W-1467mm(57.75") H-3543mm(139.50")

SPECIFICATION	PRODUCT RATING
AAMA 501-15 TAS 201/202/203-94 ASTM 1886-19 ASTM 1996-20	Design Pressure: ±2640 Pa (±55 psf) Water Penetration Resistance Test Pressure: 395 Pa (8.25 psf) Missile Level D Large Missile Impact Rated

Product Tested By: Blackwater Technical Services, Inc.

Report No: BT-DGG-23-001/W-2134

Expiration Date: May 31, 2028

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023