AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Winco Window Company
6200 Maple Ave.
St. Louis, MO 63130

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 & AAMA 450 AW-PG70-2635x2515 (104x99)-C	**AAMA 506**				
COMPANY AND CODE	Missile Level: **D** Rating: **+70/-70, 104x99** Wind Zone: **3** Rating above conforms to the requirements of: **ASTM E1886 and E1996**	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**	
Winco Window Company Code: WWC		**21905**	**1450 FIXED/CASEMENT COMBINATION (AL)(O/X.O)(IG) (INS H.S./0.090" SGP LAM GL)(MODIF)(ASTM)**	**FRAME (mm)** **2635 x 2515 (104" x 99")**	**VENT (mm)** **1010 x 1797 (40" x 71")**

This Certification will expire **April 7, 2029** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Quast Consulting & Testing, Inc.

Report No: **QCT24-7215.01**

Date of Report: **June 7, 2024**
Date Test Completed: **April 7, 2024**

Missile Impact Test & Report By:

Quast Consulting & Testing, Inc.

Report No: **QCT24-7215.01**

Date of Report: **June 7, 2024**
Date Test Completed: **April 7, 2024**

Evaluated for Certification: **June 25, 2024**

Associated Laboratories, Inc.

Authorized for Certification: **June 25, 2024**

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173

(Validator / Operations Administrator)

ACP-14 (Rev. 5/24)