



# Structural Performance Certification Authorization Report

## Lindsay Windows LLC

1995 Commerce Drive

North Mankato, MN 56003, USA

|                     |            |
|---------------------|------------|
| Certification ID:   | 20-1702    |
| Company Code:       | 020        |
| Certification Date: | 10/30/2025 |
| Revision No:        | 0          |
| Revision Date:      | 10/30/2025 |
| Expiration Date:    | 10/30/2029 |

### Product Rating Information:

|                      |                                         |       |                   |
|----------------------|-----------------------------------------|-------|-------------------|
| Model:               | 191 PVC Picture Window                  |       |                   |
| Operator Type:       | FW                                      |       |                   |
| Configuration:       | No, GS - 3/16" Temp IG                  |       |                   |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-17           |       |                   |
| Product Rating:      | Class R-PG50 1219x2413 (~48x95)-Type FW |       |                   |
| Rated Dimensions:    | Max Width:                              | 48 in | Max Height: 95 in |

### Qualifying Test Information:

|                         |            |
|-------------------------|------------|
| Test Report No:         | CCL-25-146 |
| Test Report Expiration: | 10/30/2029 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at [www.keystonecerts.com](http://www.keystonecerts.com)



### Authorized By:

Shaun Shaull  
*Shaun Shaull* 2025.10.30  
13:35:04 -04'00'

Keystone Certifications, Inc.  
145 Limekiln Rd, Suite 100B  
New Cumberland, PA 17070  
Phone: 717-932-8500



# Structural Performance Certification Authorization Report

## Revision History

| Rev # | Date       | Description       |
|-------|------------|-------------------|
| 0     | 10/30/2025 | Initial Issuance. |