

AUTHORIZATION FOR PRODUCT CERTIFICATION

Winco Window Company
6200 Maple Ave.
St. Louis, MO 63130

Attn: Lothar Erkens

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 & AAMA 450 AW-PG80-2686x1969 (106x78)-AP	AAMA 506				
COMPANY AND CODE	Missile Level: E Rating: +80/-80, 106x78 Wind Zone: 4	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Winco Window Company Code: WWC	Rating above conforms to the requirements of: ASTM E1886 and E1996	15930	3350 FIXED/AWNING COMBINATION (AL)(X/X.O/O)(IG) (INS H.S./0.180" PVB LAM GL)(MODIF)(ASTM)	<u>FRAME (mm)</u> 2686 x 1969 (8'10" x 6'6")	<u>VENTS (mm)</u> 1473 x 864 (4'10" x 2'10")

This Certification will expire **May 30, 2026 (extended from December 4, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**Mid America Testing Laboratory, Inc. &
Fenestration Testing Laboratory, Inc.**

Report No: **13146I & 9199**

Date of Reports: **March 6, 2014; September 22, 2016**


Missile Impact Test & Report By:

Fenestration Testing Laboratory, Inc.

Report No: **9199**

Date of Report: **September 22, 2016**

Evaluated for Certification: **July 26, 2022**


Associated Laboratories, Inc.

Authorized for Certification: **July 26, 2022**



Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)