AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Vytex Windows
9425 Washington Blvd. N.
Laurel, MD 20723

This authorization is based on the successful completion of tests and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-17 LC-PG55-2134x1524 (84x60)-FW	**AAMA 506**			
COMPANY AND CODE	Missile Level: **D** Rating: **+55/-55, 84x60** Wind Zone: **3** Rating above conforms to requirements of: **ASTM E1886 and E1996**	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**
Vytex Windows Code: VYW		**22007**	**6000 IMPACT PICTURE (PVC)(O)(IG) (INS 0.090" PVB LAM GL) (ASTM)**	**FRAME 2134 mm x 1524 mm (84" x 60")**

This Certification will expire **April 24, 2029** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Molimo, LLC

Report No: **28539.02-106-11**

Date of Report: **June 14, 2024**
Date Test Completed: **May 30, 2024**

Missile Impact Test & Report By:

Molimo, LLC

Report No: **28539.01-106-13**

Date of Report: **May 7, 2024**
Date Test Completed: **April 24, 2024**

Evaluated for Certification: **August 30, 2024**

Associated Laboratories, Inc.

Authorized for Certification: **August 30, 2024**

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173

(Validator / Operations Administrator)

ACP-14 (Rev. 5/24)