



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Vytex Windows
9425 Washington Blvd. N.
Laurel, MD 20723

This authorization is based on the successful completion of tests and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-22 LC-PG55-2134x1524 (84x60)-FW	AAMA 506			
COMPANY AND CODE	Missile Level: D Rating: +55/-55, 84x60 Wind Zone: 3	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
Vytex Windows Code: VYW	Rating above conforms to requirements of: ASTM E1886 and E1996	22312	3300 NARROW PW (PVC)(O)(IG) (INS 0.090" SGP LAM GL) (ASTM)	FRAME 2134 mm x 1524 mm (84" x 60")

This Certification will expire **January 20, 2030** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Molimo, LLC

Report No: **30144.01-106-11**

Date of Report: **February 11, 2025**

Date Test Completed: **January 20, 2025**

Missile Impact Test & Report By:


Molimo, LLC

Report No: **30144.02-106-11**

Date of Report: **February 11, 2025**

Date Test Completed: **January 21, 2025**

Evaluated for Certification: **February 14, 2025**


Associated Laboratories, Inc.

Authorized for Certification: **February 14, 2025**



Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)

ACP-14 (Rev. 5/24)