NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016330.02-R1**
DATE:	**09/10/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**08/03/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**Series "Contours Steel Wood Swinging Door Inswing 1 Panel"** **Opaque Steel Inswing Side Hinged Door** Configuration: X Frame: W-953mm(37.50"") H-2464mm(97") Panel: W-908mm(35.75") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **CSA A440S1-17**	**Class LC-PG50 953 x 2464 (38 x 97)-LWSHD X** **Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2640 Pa (55 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Molimo, LLC
Report No: 29078.01-201-12/L4600.01-301-47
Expiration Date: **July 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com