# AAMA CERTIFICATION PROGRAM

**An FGIA Product Certification Program**

**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**NT Window, Inc.**
**2900 W. Seminary Dr.**
**Ft. Worth, TX 76133**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATIONS | | RECORD OF PRODUCT TESTED | | | |
|---|---|---|---|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG50-2743x1651 (108x65)-HS** | **AAMA 506** | | | | |
| **COMPANY AND CODE** | Missile Level: **D**<br>Rating: **+50/-50, 108x65**<br>Wind Zone: **3**<br><br>Rating above conforms to the requirements of: **ASTM E1886 and E1996** | **CPD NO.** | **SERIES MODEL & PRODUCT DESCRIPTION** | **MAXIMUM SIZE TESTED** | |
| **NT Window, Inc.**<br>**Code: NT** | | **20168** | **G140 HS (FIN & FINLESS) (PVC)(XOX)(OG) (INS 0.090" PVB LAM GL) (MODIF)(REINF)(ASTM)** | **FRAME (mm)**<br>**2743 x 1651**<br>**(108" x 65")** | **SASH (mm)**<br>**905 x 1561**<br>**(35" x 61")** |

This Certification will expire **July 12, 2029 (extended from July 12, 2024 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**Intertek B&C**

Report No: **J4324.05-501-44**

Date of Report: **April 26, 2022**
Date Test Completed: **July 19, 2019**

Missile Impact Test & Report By:

**Intertek B&C**

Report No: **J4324.06-501-44**

Date of Report: **April 26, 2022**
Date Test Completed: **July 12, 2019**

Evaluated for Certification: **April 25, 2024**

Associated Laboratories, Inc.

Authorized for Certification: **April 25, 2024**

Fenestration and Glazing Industry Alliance

(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)