

Hallmark® Certificate of Conformance and License (CCL)



Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453
For more Information visit www.amscert.com
Website: www.windsorwindows.com
TEL: 515-223-6660

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
453-H-084.00	Next Dimension Casement	101/I.S.2/A440-22	Class LC-PG50; Size Tested 35.500" x 71.500" Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	35.500"	71.500"	ESP039738P NAFS	3/16/2024	4/1/2024	6/1/2033
453-H-084.01	Next Dimension Casement	AAMA 1701.2-12	Class LC-PG50; Size Tested 35.500" x 71.500" Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	35.500"	71.500"	ESP039738P HUD	3/16/2024	4/1/2024	6/1/2033
453-H-084.02	Next Dimension Casement	AAMA 1704-12	Class LC-PG50; Size Tested 35.500" x 71.500" Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	35.500"	71.500"	ESP039738P HUD	3/16/2024	4/1/2024	6/1/2033
453-H-084.03	Next Dimension Casement	ASTM E-1996-20 / ASTM E-1886-19	DP +60/-60 psf, Missile D, Wind Zone 3	35.500"	71.500"	ESP039738P ASTM	3/11/2024	4/1/2024	1/17/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee* John McFee, VP of Certification Programs, WDMA Hallmark

By: *Lucas L. Wenzel* Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com