

Hallmark® Certificate of Conformance and License (CCL)



Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453

For more Information visit www.amscert.com

Website: www.windsorwindows.com

TEL: 515-223-6660

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
453-H-087.00	Next Dimension Single-Hung	101/I.S.2/A440-22	Class LC-PG50; Size Tested 35,500 in x 71,500 in Type-H*; DP +50/-50 psf; Water Test Press 50; Can. Air Infil/Exfil. Level=A2	35,500 in	71,500 in	ESP038496.1 NAFS	7/5/2024	7/24/2024	5/21/2034
453-H-087.01	Next Dimension Single-Hung	101/I.S.2/A440-22	Class LC-PG50; Size Tested 53,500 in x 83,500 in Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2	53,500 in	83,500 in	ESP038496.2 NAFS	7/5/2024	7/24/2024	1/19/2034
453-H-087.02	Next Dimension Single-Hung	ASTM E-1996-20 / ASTM E-1886-19	DP +60/-60 psf, Missile D, Wind Zone 3	53,500 in	83,500 in	ESP038496P.Rev. ASTM	2/13/2026	7/29/2024	5/20/2034
453-H-087.03	Next Dimension Single-Hung	ASTM E-1996-20 / ASTM E-1886-19	DP +60/-60 psf, Missile D, Wind Zone 3	53,500 in	83,500 in	ESP038496 ASTM	7/22/2024	7/29/2024	5/9/2034
453-H-087.04	Next Dimension Single-Hung	AAMA 1701.2-12	Pass	53,500 in	83,500 in	ESP038496P.2 HUD	7/5/2024	7/29/2024	1/19/2034
453-H-087.05	Next Dimension Single-Hung	AAMA 1704-12	Pass	53,500 in	83,500 in	ESP038496P.2 HUD	7/5/2024	7/29/2024	1/19/2034
453-H-087.06	Next Dimension Single-Hung	AAMA 1701.2-12	Pass	35,500 in	71,500 in	ESP038496P.1 HUD	7/5/2024	7/29/2024	5/21/2034
453-H-087.07	Next Dimension Single-Hung	AAMA 1704-12	Pass	35,500 in	71,500 in	ESP038496P.1 HUD	7/5/2024	7/29/2024	5/21/2034
453-H-087.24	Next Dimension Single-Hung	101/I.S.2/A440-22	Class LC-PG60; Size Tested 53,500 in x 71,500 in * Type-H; DP +60/-60 psf; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A3	53,500 in	71,500 in	ESP042338P.14Rev	1/9/2026	12/30/2025	8/12/2035

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453

For more Information visit www.amscert.com

Website: www.windsorwindows.com

TEL: 515-223-6660

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	---------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee John McFee, VP of Certification Programs, WDMA Hallmark

By: Lucas L. Wenzel Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com