

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016836
DATE: 10/28/2025
CERTIFICATION PROGRAM: Structural
COMPANY: ABI Windows
CODE: 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ABI Windows, LLC 1121 Fulwiler Road Abilene, Texas 79603	Series "500" Vinyl Horizontal Sliding Window Configuration: OX Glazing: IG - 1/8" Annealed Glass/1/8" Annealed Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Annealed Glass Frame: W-1511mm(59.5") H-1207mm(47.5") Vent: W-730mm(28.75") H-1133mm(44.63") DLO: W-676mm(26.63") H-1118mm(44")

SPECIFICATION	PRODUCT RATING
ASTM E330-21 ASTM E1886-19 ASTM E1996-23	Design Pressure: ±2394 Pa (±50 psf) Wind Zone 3 - Missile Level D

Product Tested By: Construction Consulting Laboratory
Report No: CCL 25-199
Expiration Date: August 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
NAMI@namiinc.com

NOPC - 03/30/2023