

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016459-R1
DATE: 01/08/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1
REVISION DATE: 02/04/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	“Impact-Rated Opaque Fiberglass Side-Hinged Door Assembly w/Composite Jamb Sidelite Sills” (w/ Sidelites) Configuration: OXO Glazing: IG-1/8" Tempered Glass/5/32" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-2858mm(115.5") H-2489mm(98") Panel: W-911mm(35.88") H-2419mm(95.25") DLO: W-530mm(20.88") H-2004mm(78.88")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-14 ASTM E331-00 ASTM E1886-19/ASTM E1996-20 TAS 201/202/203-94	Design Pressure: ±2394 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01463913A/TEL 01463913
Expiration Date: November 30, 2028

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023