

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016460.02
DATE: 02/11/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation 118 Industrial Drive Edgerton, OH 43517	“Fiberglass Side Hinged Door Assembly w/Composite Jamb Sidelite Sills” w/ Sidelites Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-2858mm(112.5") H-2489mm(98") Panel: W-911mm(35.88") H-2419mm(95.25") DLO: W-530mm(20.88") H-2004mm(78.88")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-14 ASTM E331-00	Design Pressure: ±2155 Pa (45 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01463913B
Expiration Date: November 30, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023