

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016330.06
DATE: 02/11/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Contours Steel Wood Edge Swinging Door" Glazed Steel Inswing Side Hinged Door Configuration: X Frame: W-953mm(37.50") H-2078mm(81.75") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-530mm(20.88") H-1594mm(62.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-17	Class LC-PG50 953 x 2078 (38 x 82)-LW SHD X Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Molimo, LLC
Report No: 29695.01-201-12/30069.01-201-12
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016330.07
DATE: 02/11/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Contours Steel Wood Edge Swinging Door" Glazed Steel Outswing Side Hinged Door Configuration: X Frame: W-953mm(37.50") H-2045mm(80.50") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-530mm(20.88") H-1594mm(62.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-17	Class LC-PG50 953 x 2045 (38 x 81)-LW SHD X Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Molimo, LLC
Report No: 29696.01-201-12/30069.01-201-12
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023