

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016332.01-R2
DATE: 09/17/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Masonite
CODE: 1823-1
REVISION DATE: 09/09/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Masonite International 1955 Powis Road West Chicago, IL 60185	Flush Glazed Fiberglass Outswing Fiberglass Side-Hinged Door Assembly w/Sidelites Configuration: OXXO Glazing: IG-5/32" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-3785mm(149") H-2048mm(80.63") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-635mm(25") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 ASTM E283-04 ASTM E331-00 TAS 202-94 (Limited Water) TAS 201/203-94	Positive Design Pressure: (60 psf) Negative Design Pressure:(55 psf) Water Penetration Resistance Test Pressure: 5.25 psf ¹ Water Penetration Resistance Test Pressure: 6.0 psf ² Water Penetration Resistance Test Pressure: 7.05 psf ³ Water Penetration Resistance Test Pressure: 7.5 psf ⁴ Water Penetration Resistance Test Pressure: 9.0 psf ⁵ Water Penetration Resistance Test Pressure: 8.25 psf ⁶ Large Missile Impact Rated

Note: 1: Bumper Threshold / 2 - Z-Series Threshold / 3 - High Dam Threshold/4- HP Outswing Threshold for Single Door Only/
5- HBP Outswing Threshold for Single Door Only /6- HBP Outswing Threshold for XX, OX &OXO

Product Tested By: **American Test Lab, Inc. (ATLNC)**
Report No: **ATLNC 0604.01-24/W-1842/W-1878/W-2107/W-2130/W-1860**
Anchor Detail -MA-FL 0270W-2203
Expiration Date: **June 30, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023