

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016332.02  
DATE: 10/17/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Masonite  
CODE: 1823-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                 | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                                                                                                           |
|------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Masonite International</b><br><b>1955 Powis Road</b><br><b>West Chicago, IL 60185</b> | <b>Flush Glazed Fiberglass Inswing</b><br><b>Fiberglass Side-Hinged Door Assembly</b><br><b>w/Sidelites &amp; Multipoint Lock</b><br><br>Configuration: OXXO<br>Glazing: IG-5/32" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Heat Strengthened Glass<br><br>Frame: W-3785mm(149") H-2080mm(81.88")<br>Panel: W-908mm(35.75") H-2013mm(79.25")<br>DLO: W-635mm(25") H-1600mm(63") |

| SPECIFICATION                                                                                                                             | PRODUCT RATING                                                                                                                   |
|-------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------|
| <b>ASTM E330-14</b><br><b>ASTM E283-04</b><br><b>ASTM E331-00</b><br><b>TAS 202-94</b><br><b>(Limited Water)</b><br><b>TAS 201/203-94</b> | <b>Design Pressure: ±50 psf</b><br><b>Water Penetration Resistance Test Pressure: 0 psf</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: American Test Lab, Inc. (ATLNC)  
Report No: ATLNC 0604.01-24/W-1842/W-1878/W-1972/W-2107/Anchor Detail - MA-FL 0270  
Expiration Date: **June 30, 2028**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023