

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016332
DATE: 09/17/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Masonite
CODE: 1823-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Masonite International 1955 Powis Road West Chicago, IL 60185	Flush Glazed Fiberglass Inswing Fiberglass Side-Hinged Door Assembly w/Sidelites Configuration: OXXO Glazing: IG-5/32" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-3785mm(149") H-2080mm(81.88") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-635mm(25") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 ASTM E283-04 ASTM E331-00 TAS 202-94 (Limited Water) TAS 201/203-94	Positive Design Pressure: 55 psf Negative Design Pressure: 60 psf Water Penetration Resistance Test Pressure: 0 psf Large Missile Impact Rated

Product Tested By: American Test Lab, Inc. (ATLNC)
Report No: ATLNC 0604.01-24/W-1842/W-1878/W-1972/W-2107/Anchor Detail - MA-FL 0270
Expiration Date: **June 30, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023