

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016615.01-R1
DATE: 04/21/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Jiangxi Fangda
CODE: 3123-1
REVISION DATE: 05/15/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Jiangxi Fangda Tech Co., Ltd Tongjiang West Road, Chihu Ind. Park Jiujiang City, Jiangxi Prov., China 332000	Opaque Steel Flush or Embossed Outswing Side Hinged Door (w/ or w/o Flat Threshold) Configuration: X Frame: W-958mm(37.75") H-2471mm(97.25") Panel: W-914mm(36") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +50/-50 psf Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf) Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: 250122005SHF-001/W-2161
Expiration Date: **April 30, 2029**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023