Structural Performance
Certification Authorization Report

Yawal USA

Lubliniecka 36
Herby, 42-272, Poland

Certification ID:	1286-107
Company Code:	1286
Certification Date:	3/31/2022
Revision No:	0
Revision Date:	3/31/2022
Expiration Date:	3/31/2026

Product Rating Information:

Model:	DP 180-Sliding Door			
Operator Type:	SD			
Configuration:	Clip/EM/IM, GS - 5/16" Temp IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-17/S1-19			
Product Rating:	Class LC-PG40 6096x3048 (240x120)-Type SD			
Rated Dimensions:	**Max Width:**	240 in	**Max Height:**	120 in

Qualifying Test information:

Test Report No:	NCTL 210-4255-07 Rev1
Test Report Expiration:	3/31/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com

Authorized By:

Digitally signed by Jon Hill
Date: 2022.03.31 14:41:37 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500

Revision History

Rev #	Date	Description
0	3/31/2022	Initial issuance