

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016673
DATE: 06/12/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "4500" Aluminum PTAC Louver Assembly Configuration: O Frame: W-645mm(25.38") H-1918mm(75.5") DLO: W-530mm(20.88") H-1803mm(71")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 (2021)	Design Pressure: ±2880 Pa (60 psf)

Product Tested By: Molimo Architectural Product Testing
Report No: 30832.01-109-122
Expiration Date: May 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC 03/30/2023