WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

VELUX America LLC
450 Old Brickyard Rd
PO Box 5001
Greenwood, SC 29649

Mfr ID: 426
For more Information visit www.amscert.com
Website: www.veluxusa.com
TEL: 864-941-5309

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
426-H-732.36	SFHD 4646 (or smaller) Double Dome Polycarb High Pan Self-flashed Skylight	101/I.S.2/A440-17	Class PG-PG95; Size Tested 1490mm x 1490mm Type-SKP; DP +95/-186 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	1490mm	1490mm	R5762.03-450-44	1/24/2025	3/10/2025	12/26/2034
426-H-732.37	SFHD 4646 (or smaller) Double Dome Polycarb High Pan Self-flashed Skylight	101/I.S.2/A440-11	Class PG-PG95; Size Tested 1490mm x 1490mm Type-SKP; DP +95/-186 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	1490mm	1490mm	R5762.03-450-44	1/24/2025	3/10/2025	12/26/2034
426-H-732.42	SFHD 4646 (or smaller) Double Dome Polycarb High Pan Self-flashed Skylight	TAS 201/202/203-94	DP +60/-60 psf, Missile D, Wind Zone 4, Large Missile, +80/-80 psf Cycle Pressure	1387mm	1387mm	R5760.03-450-18-r0	1/9/2025	3/10/2025	10/8/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com

ANAB
ANSI National Accreditation Board
ACCREDITED
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#0961