Hallmark® Certificate of Conformance and License (CCL)

WINDOW & DOOR MANUFACTURERS ASSOCIATION WDMA

AMS, INC. Administrative Management Systems, Inc.

VELUX America LLC
450 Old Brickyard Rd
PO Box 5001
Greenwood, SC 29649

Mfr ID: 426
For more Information visit www.amscert.com
Website: www.veluxusa.com
TEL: 864-941-5309

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
426-H-732.08	SFRD/SFDA 2246 (or smaller) Double Dome Polycarb Self-Flashed Skylight	101/I.S.2/A440-17	Class PG-PG100; Size Tested 780mm x 1490mm Type-SKP; DP +100/-200 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	780mm	1490mm	R5518.04-550-44	2/21/2025	3/4/2025	9/18/2034
426-H-732.09	SFRD/SFDA 2246 (or smaller) Double Dome Polycarb Self-Flashed Skylight	101/I.S.2/A440-11	Class PG-PG100; Size Tested 780mm x 1490mm Type-SKP; DP +100/-200 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	780mm	1490mm	R5518.04-550-44	2/21/2025	3/4/2025	9/18/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com