

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016834-R1
DATE: 10/27/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Cantera
CODE: 549-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Cantera Doors 22108 Hwy-71 West Suite 4-404 Spicewood, TX 78669	Steel Triple Fixed Windows (w or w/o True-Divided Lites) Configuration: OOO Glazing: Monolithic-1/4" Heat-Strengthened Glass/0.090" Kuraray SentryGlas Interlayer/1/4" Heat Strengthened Glass Frame: W-5258mm(207") H-3048mm(120") DLO: W-1578mm(62.13") H-2864mm(112.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 TAS 201/202/203-94	Class LC-PG65 5258 x 3048 (207 x 120)-FW Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Large Missile Impact Rated

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2829T0002A/2829T0002B/W-2187
Expiration Date: May 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023