

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016834.01
DATE: 01/12/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Cantera
CODE: 549-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Cantera Doors 22108 Hwy-71 West Suite 4-404 Spicewood, TX 78669	Steel Fixed Window (Roundtop) Configuration: O Glazing: Monolithic-1/4" Heat-Strengthened Glass/0.090" Kuraray SentryGlas Interlayer/1/4" Heat Strengthened Glass Frame: W-457mm(18") H-2184mm(86") DLO: W-283mm(11.13") H-2010mm(79.13")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3120 Pa (±65 psf) Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) Large Missile Impact Rated

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2829T0002A/2829T0002B/2829T0002C/W-2178
Expiration Date: May 31, 2029

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023