

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016833.01
DATE: 10/27/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Cantera
CODE: 549-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Cantera Doors 22108 Hwy-71 West Suite 4-404 Spicewood, TX 78669	Steel Double Outswing Doors Steel Outswing Double Side Hinged Doors (w/Sidelite) Configuration: XXO Glazing: Monolithic-1/4" Heat-Strengthened Glass/0.090" Kuraray SentryGlas Interlayer/1/4" Heat Strengthened Glass Frame: W-3886mm(153") H-3048mm(120") Panel: W-1022mm(40.25") H-2980mm(117.31") DLO: W-892mm(35.13") H-2831mm(111.44")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 TAS 201/202/203-94	Class LC-PG75 3886 x 3048 (153 x 120)-SHD Design Pressure: ±3600 Pa (±75 psf) Water Penetration Resistance Test Pressure: 540 Pa (11.30 psf) Large Missile Impact Rated

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2829T0003A
Expiration Date: October 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023