

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016833.04  
DATE: 02/04/2026  
CERTIFICATION PROGRAM: Structural  
COMPANY: Cantera  
CODE: 549-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                   | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                                                                                   |
|--------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Cantera Doors</b><br><b>22108 Hwy-71 West Suite 4-404</b><br><b>Spicewood, TX 78669</b> | <b>Steel Double Outswing Doors</b><br><b>Steel Outswing Double Side Hinged Doors</b><br><b>(w/Sidelite)</b><br><br>Configuration: OXXO<br>Glazing: Monolithic-1/4" Heat-Strengthened<br>Glass/0.090" Kuraray SentryGlas Interlayer/1/4" Heat<br>Strengthened Glass<br><br>Frame: W-5639mm(222") H-3048mm(120")<br>Panel: W-1022mm(40.25") H-2980mm(117.31")<br>DLO: W-892mm(35.13") H-2831mm(111.44") |

| SPECIFICATION             | PRODUCT RATING                                                                                                                                           |
|---------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>TAS 201/202/203-94</b> | <b>Design Pressure: ±3600 Pa (±75 psf)</b><br><b>Water Penetration Resistance Test Pressure: 540 Pa (11.30 psf)</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: PRI Construction Materials Technologies, LLC  
Report No: 2829T0003A/W-2181  
Expiration Date: October 31, 2029

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023