WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413
For more Information visit www.amscert.com
Website: www.kolbewindows.com
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1070.144	Vistaluxe Stretta Sliding Door, 2 Wide with Stationary Panel, SP (R&D 24101)	101/I.S.2/A440-22	Class LC-PG60; Size Tested 2435mm x 2505mm Type-SD; DP +60/-60 psf; Water Test Press 470Pa (9.82psf)	2435mm	2505mm	QCT24-7203.42	1/28/2025	4/9/2025	12/19/2034
413-H-1070.145	Vistaluxe Stretta Sliding Door, 2 Wide with Stationary Panel, SP (R&D 24101)	101/I.S.2/A440-17	Class LC-PG60; Size Tested 2435mm x 2505mm Type-SD; DP +60/-60 psf; Water Test Press 470Pa (9.82psf)	2435mm	2505mm	QCT24-7203.42	1/28/2025	4/9/2025	12/19/2034
413-H-1070.146	Vistaluxe Stretta Sliding Door, 2 Wide with Stationary Panel, SP (R&D 24101)	CSA A440 S1-19	Class LC-PG60; Size Tested 2435mm x 2505mm Type-SD; DP +2880/-2880 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A2	2435mm	2505mm	QCT24-7203.42	1/28/2025	4/9/2025	12/19/2034
413-H-1070.147	Vistaluxe Stretta Sliding Door, 2 Wide with Stationary Panel, SP (R&D 24101)	CSA A440 S1-17	Class LC-PG60; Size Tested 2435mm x 2505mm Type-SD; DP +2880/-2880 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A2	2435mm	2505mm	QCT24-7203.42	1/28/2025	4/9/2025	12/19/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com

ANAB
ANSI National Accreditation Board
ACCREDITED
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#0961