WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413
For more Information visit www.amscert.com
Website: www.kolbewindows.com
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1070.159	Vistaluxe Stretta Sliding Door, 4 Wide with Stationary Panel, SP (R&D 24105)	101/I.S.2/A440-22	Class LC-PG30; Size Tested 4799mm x 2505mm Type-SD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	4799mm	2505mm	QCT25-7496.14	7/23/2025	7/28/2025	7/1/2035
413-H-1070.160	Vistaluxe Stretta Sliding Door, 4 Wide with Stationary Panel, SP (R&D 24105)	101/I.S.2/A440-17	Class LC-PG30; Size Tested 4799mm x 2505mm Type-SD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	4799mm	2505mm	QCT25-7496.14	7/23/2025	7/28/2025	7/1/2035
413-H-1070.161	Vistaluxe Stretta Sliding Door, 4 Wide with Stationary Panel, SP (R&D 24105)	CSA A440 S1-19	Class LC-PG30; Size Tested 4799mm x 2505mm Type-SD; DP +1440/-1440 Pa (+30.1/-30.1 psf); Water Test Press 220Pa (4.59psf); Can. Air Infil/Exfil. Level=A3	4799mm	2505mm	QCT25-7496.14	7/23/2025	7/28/2025	7/1/2035

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com