

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016330.12
DATE: 06/05/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series “Contours (S-2500) Steel Wood Swinging Door” Opaque Steel Inswing Side Hinged Door Configuration: X Frame: W-949mm(37.38") H-2483mm(97.75") Panel: W-908mm(35.75") H-2416mm(95.13")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 TAS 202-94 (Structural Only)	Design Pressure: +65/-70 psf Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 30439.01-201-12
Expiration Date: April 30, 2029

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016330.13
DATE: 06/05/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Contours (S-2500) Steel Wood Swinging Door" Opaque Steel Outswing Side Hinged Door Configuration: X Frame: W-949mm(37.38") H-2451mm(96.50") Panel: W-908mm(35.75") H-2416mm(95.13")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 TAS 202-94 (Structural Only)	Design Pressure: +65/-70 psf Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 30439.01-201-12
Expiration Date: April 30, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016330.14
DATE: 06/05/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Contours (S-2500) Steel Wood Swinging Door" Opaque Steel Inswing Side Hinged Door Configuration: X Frame: W-953mm(37.50") H-2076mm(81.75") Panel: W-908mm(35.75") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 TAS 202-94 (Structural Only)	Design Pressure: +65/-65 psf Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 30683.01-201-12
Expiration Date: April 30, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016330.15
DATE: 06/05/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series “Contours (S-2500) Steel Wood Swinging Door” Opaque Steel Outswing Side Hinged Door Configuration: X Frame: W-953mm(37.50") H-2045mm(80.50") Panel: W-908mm(35.75") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 TAS 202-94 (Structural Only)	Design Pressure: +65/-65 psf Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 30683.01-201-12
Expiration Date: April 30, 2029

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023