

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016330.09-R1
DATE: 03/10/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 08/20/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Contour Steel Wood Edge Swinging Door" Glazed Steel Outswing Side Hinged Door Configuration: X Glazing: IG-Ext. 1/8" Annealed Glass/0.090" PVB Interlayer by Kuraray/1/8" Annealed Glass/1/8" Annealed Glass/Int. 1/8" Tempered Glass Frame: W-953mm(37.50") H-2045mm(80.50") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-530mm(20.88") H-1594mm(62.75")

SPECIFICATION	PRODUCT RATING
TAS 201-94 TAS 202-94 TAS 203-94	Design Pressure: +65/-70 psf Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 29469.01-201-12/29468.01-201-12
Expiration Date: **February 28, 2030**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023