NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016330.15-R1**
DATE:	**06/05/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**08/20/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**Series "Contours (S-2500) Steel Wood Swinging Door"** **Opaque Steel Outswing Side Hinged Door** Configuration: X Frame: W-953mm(37.50") H-2045mm(80.50") Panel: W-908mm(35.75") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 **TAS 202-94 (Structural Only)**	**Design Pressure: +65/-65 psf** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)** **Large Missile Impact Rated**

Product Tested By: Molimo, LLC
Report No: 30683.01-201-12
Expiration Date: **April 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com