WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

# Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

*Mfr ID:* 453
*For more Information visit www.amscert.com*
*Website:* www.windsorwindows.com
*TEL:* 515-223-6660

| Product No. | Product Name | Standard | Rating | Wide | High | Test Report # | RptDate | CertDate | ExpDate |
|---|---|---|---|---|---|---|---|---|---|
| 453-H-091.04 | Next Dimension Narrow Sliding Door | 101/I.S.2/A440-22 | Class LC-PG25; Size Tested 141.375 in x 95.500 in Type-SD; DP +25/-25 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A2 | 141.375 in | 95.500 in | PUS23001044.1 | 4/18/2026 | 5/28/2026 | 1/30/2036 |

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

**By:** *John McFee, VP of Certification Programs, WDMA Hallmark*

**By:** *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com



ANAB
ANSI National Accreditation Board
ACCREDITED
ISO/IEC 17065
PRODUCT CERTIFICATION BODY
#0961