

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Windsor Windows and Doors
900 South 19th Street
West Des Moines, IA 50265

Mfr ID: 453


For more Information visit www.amscert.com


Website: www.windsorwindows.com

TEL: 515-223-6660

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
453-H-095.02	Next Dimension French Impact Sidelite	ASTM E-1996-23 / ASTM E-1886-19	DP +50/-50 psf, Missile D, Wind Zone 3	47.500 in	95.500 in	ESP042691P.2 ASTM	11/10/2025	12/11/2025	10/21/2035
453-H-095.03	Next Dimension French Impact Sidelite	ASTM E-330-14	DP +50/-50 psf	47.500 in	95.500 in	ESP042691P.2 CLIP	11/10/2025	12/30/2025	9/3/2035
453-H-095.04	Next Dimension French Impact Sidelite	ASTM E-330-14	DP +50/-50 psf	47.500 in	95.500 in	ESP042691P.2 SCREW	11/10/2025	12/11/2025	9/3/2035

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com