NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016582**
DATE:	**04/07/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Hy-Lite**
CODE:	**3155-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hy-Lite Specialty Products **3000 E. Johnson Avenue** **Pensacola, Florida 32514**	**Series "V1500/1580-6"** **Viny Fixed Window** Configuration: O Glazing: 6" x 6" x 1.5" Acrylic Block - Qty. 144 Frame: W-1880mm (74") H-1880mm (74") DLO: W-1803mm (71") H-1803mm (71")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class LC-PG30 1880 x 1880 (74 x 74)-FW** **Design Pressure: ±1440 Pa (±30 psf)** **Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf)** **Canadian Air Infiltration/Exfiltration Level: Fixed**

Product Tested By: Intertek, PLC.
Report No: K5255.03-550-44
Expiration Date: **April 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com