

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016582.01
DATE: 04/07/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Hy-Lite
CODE: 3155-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hy-Lite Specialty Products 3000 E. Johnson Avenue Pensacola, Florida 32514	Series "V1500/1580-6" Vinyl Fixed Window Configuration: O Glazing: 6" x 6" x 1.5" Acrylic Block - Qty. 144 Frame: W-1422mm (56") H-1422mm (56") DLO: W-1340mm (52.75") H-1340mm (52.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG60 1422 x 1422 (56 x 56)-FW Design Pressure: ± 2880 Pa (± 60 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC.
Report No: K5255.03-550-44
Expiration Date: April 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023